



Client name: \_\_\_\_\_

Fill Up Date: \_\_\_\_\_

PRIMARY VOLTAGE IN KV	NUMBER OF PRIMARY BUSHINGS	KVA	SECONDARY VOLTAGE	NUMBER OF SECONDARY BUSHINGS	KV BIL	FRE-QUENCY	PRIMARY BUSHING CLASS IN KV	PRIMARY PROTECTION	OPTIONS LIST
Range from 2.4KV to 22.9KV	<b>1</b> 1 Bushing	<b>1</b> 1.0KVA	<b>20</b> 120 Volt	<b>1</b> 1 Eyebolt Bushing	<b>A</b> 75BIL	<b>1</b> 50hz	<b>A</b> 15KV (95BIL)	<b>N</b> No Fuse	<b>G</b> Arrestor Bosses
			<b>40</b> 240 Volt						<b>H</b> 2 Hanger Brackets
	<b>2</b> 2 Bushings	<b>2</b> 1.5KVA	<b>50</b> 120/240 Volt	<b>2</b> 2 Eyebolt Bushings	<b>B</b> 95BIL	<b>2</b> 60hz	<b>B</b> 18KV (125BIL)	<b>F</b> Fused	<b>J</b> SS Tank
			<b>60</b> 480 Volt						<b>K</b> Painted SS Tank
			<b>70</b> 230 Volt						<b>L</b> Reverse Primary Bushing
	<b>3</b> 1 Bushing Well	<b>3</b> 2.0KVA	<b>80</b> 115 Volt	<b>3</b> 3 Eyebolt Bushings	<b>C</b> 125BIL		<b>C</b> 23KV (150BIL)		<b>M</b> Negative Polarity
			<b>85</b> 110 Volt						<b>N</b> Cover Ground Strap
	<b>4</b> 2 Bushing Wells	<b>5</b> .5KVA	<b>90</b> 220 Volt	<b>8</b> 5-pin Bendix	<b>D</b> 150BIL		<b>D</b> 18KV (110BIL)		<b>P</b> Secondary Ground Strap
			<b>95</b> 250 Volt						<b>Q</b> Primary Handwheel Guard
		<b>6</b> 2.5KVA			<b>E</b> 110BIL				<b>R</b> Snap on Primary Guard
								<b>S</b> Reverse H1 Stamp	

- CHARACTERISTICS:**
- 65 C Rise
  - Type OISC
  - CU Windings
  - No PCB's
  - 9" Tank Diameter
  - Sky Grey Powder Coating



- PRIMARY BUSHING RATINGS:**
- 15KV Class-5 Flange-12" Creep -95 BIL
  - 18KV Class-7 Flange-19" Creep-125 BIL
  - 23KV Class-10 Flange-30" Creep-150 BIL

PLEASE CONSULT SALES OFFICE FOR VOLTAGES, SIZES AND BUSHING ARRANGEMENTS

AVAILABLE OR TO REQUEST SPEC INFORMATION ON SPECIFIC TRANSFORMER CONFIGURATIONS.

- T** FR3 Fluid
- U** FR3 Label
- V** No PCB Label
- X** Stencil
- W** Test Reports Required
- Z12** 1.2% Impedance
- Z20** 2.0% Impedance
- Z27** 2.7% Impedance
- Z30** 3.0% Impedance